

**NOTES**

- ALL FIRE HYDRANTS ARE Ø100 SPRING U.N.O.
- ALL WATER SERVICE PIPE CONDUITS ARE Ø100 PVC PN20 U.N.O.
- ALL DICL PIPES ARE PN35
- ALL WATER MAINS PIPES ARE PN16 U.N.O.

**REGISTERED SURVEYOR'S CERTIFICATION**

LandPartners Pty Ltd hereby certify that the vertical and horizontal locations and dimensions shown on this plan are a true and correct record and were located by survey.

*R. P. [Signature]* (Director)  
 LandPartners Pty Ltd, Reg. Surveyor No. S4118 Date: 29/11/2022

**ENGINEERS CERTIFICATION**

I, \_\_\_\_\_, hereby certify that:


- The information contained in this drawing / document is in compliance with approved drawings and design.
- The new water and sewerage works defined by this drawing have been designed and constructed in accordance with the SEQ Code.
- This represents an accurate record of as-constructed works.
- I accept responsibility for the information contained in this drawing / document.

RPEQ (signature) RPEQ No. \_\_\_\_\_ Date: \_\_\_\_\_

**LEGEND**

●	(FH) FIRE HYDRANT
⊗	(VS) STOP VALVE
⊗	(VA) SCOUR ASSEMBLY
□	(TB) TAPPING BAND
×	(WM) WATER METER (SEQ 20 Ø)
⊥	END CAP
△	TEE
∧	REDUCER
○	BEND
—	DICL WATER MAIN CROSSING
=====	CONDUIT/CROSSING
—	EXISTING WATER

**AS CONSTRUCTED**



<b>A1</b>	1	29/11/2022	INITIAL ISSUE	VO	RA	RM
	INDEX	DATE	REVISIONS	DRAWN	CHECKED	PASSED

DRAWN	VO	29/11/2022
CHECKED	RA	29/11/2022
PASSED	RM	29/11/2022
INITIALS	DATE	



**Queensland Urban Utilities**

AURORA STAGE 2  
 AS CONSTRUCTED WATER  
 21-PNT-53347

SCALE 1:500  
 SHEET 1 OF 1 SHEETS  
 DRAWING NO.  
 BRSS5365-002-69-1